

## Appendix B - International Fire Building Code Amendments

The International Fire Building Code shall be amended as follows:

Section 901.4      **Installation.** This section shall be amended by adding the following:

A fire alarm system shall be installed and maintained in full operating condition in all occupancies. Systems shall be installed in all new structures and in those whose renovation involves at least 25% of the floor space. Exception: R-3 and structures without electricity.

An automatic fire detection system shall be installed and maintained in full operating condition in all occupancies except as identified in Section 919.4.4 and 919.5. Systems shall be installed in all new structures and in those whose renovation involves at least 25% of the floor space.

All automatic fire suppression systems required for occupancies and all use groups shall be supervised by method 1. Systems currently in existence may continue to utilize method 2 until such time as their systems is modified. Exception 5 is hereby deleted.