

Appendix B - International Fire Building Code Amendments

(Revised Ord 2016-52)

The International Fire Building Code shall be amended as follows:

Section 907.1 **General.** This section shall be amended by adding the following:

A fire alarm system shall be installed and maintained in full operating condition in all occupancies. Systems shall be installed in all new structures and in those whose renovations involve a permit for build out or change of occupancy.